

## Smoke Control System - Maintenance Log Sheet

Site Address:

Building Name/Number:



Date	Weekly Test		Monthly Test		Comments	Signature
	Operational test of smoke control system. Check natural vents open		Simulate power failure of the primary power supply and carry out operation test.		Details of failures should be documented here and reported to the maintenance contractor	

Athena Fire Consultancy Limited

[www.athenafireconsultancy.com](http://www.athenafireconsultancy.com)

[info@athenafireconsultancy.com](mailto:info@athenafireconsultancy.com)